

Wels, October.24.2023

## OVERSIZING FRONIUS PRIMO 3.0-1 – 8.2-1

### **Fronius International GmbH**

Hereby confirms that the inverters

#### **/ Fronius Primo 3.0-1 up to Fronius Primo 8.2-1**

can be oversized 50% above the rated nameplate capacity without voiding the manufacturer's warranty, provided that

/ String configuration adheres to the voltage and current window guidelines published in the operation manual

/ The open circuit voltage of the PV generator does not exceed the maximum input voltage of the inverter under any circumstances (temperature, irradiance)

/ The maximum DC array short circuit current of the PV generator must not exceed the maximum module array short circuit current ( $I_{SC\ PV}$ ) of the inverter.  $I_{SC\ PV}$  according to IEC 60364-7-712, NEC 2020, AS/NZS 5033:2021 is defined as:  $I_{SC\ pv} = I_{SC\ max} \geq I_{SC\ (STC)} \times 1.25$   
For more detailed information, please see the technical datasheets.

### **Fronius International GmbH**

Business Unit Solar Energy

Froniusplatz 1

4600 Wels



Philipp Rechberger

Head of System Technology